

# **R1 as Efficiency Indicator Status Quo and Optimization Potential**

**Dr.- Ing. Dieter O. Reimann, Bamberg  
Scientific and Technical Advisor to CEWEP**

**To assess Waste-to-Energy (WtE) plants it has inter alia to be taken into account:**

**their energy production and export,**


**their contribution to the national energy supply,**

**their saving of resources (primary fuels saving),**

**their reduction potential of CO2 emissions (greenhouse gases, climate relevance) etc.**

# Energy balance of WtE plants

Waste-to-Energy (WtE) plants generate electricity and heat by the thermal treatment of mixed municipal solid waste (MSW).



## **Directive 2008/98/EC on Waste and Repealing Certain Directives** **(WFD)**

**includes in ANNEX II a calculation formula to determine  
if a waste incineration installation is  
a recovery operation (R1)**

**or, if not meeting the fixed R1 energy efficiency factor, is classified as  
a disposal operation (D10).**

**R1: Use principally as a fuel or other means to generate energy.**

**This includes incineration facilities dedicated to the processing of  
municipal solid waste only where their energy efficiency is equal to  
or above:**

- 0.60 for installations in operation and permitted in accordance with  
applicable Community legislation before 1 January 2009,**
- 0.65 for installations permitted after 31 December 2008,  
using the following formula<sup>1</sup>:**

$$\text{Energy efficiency} = (E_p - (E_f + E_i)) / (0.97 \times (E_w + E_f))$$

In which:

$E_p$  means annual energy produced as heat or electricity. It is calculated with energy in the form of electricity being multiplied by 2.6 and heat produced for commercial use multiplied by 1.1 (GJ/year)

$E_f$  means annual energy input to the system from fuels contributing to the production of steam (GJ/year)

$E_w$  means annual energy contained in the treated waste calculated using the lower net calorific value of the waste (GJ/year)

$E_i$  means annual energy imported excluding  $E_w$  and  $E_f$  (GJ/year)

0.97 is a factor accounting for energy losses due to bottom ash and radiation.

Reduction of volume and material recovery of residues



$$\text{Energy efficiency} = E_p / (0.97 \times E_w)$$


**R1 energy efficiency is a non-dimensional factor  
based on  
the 1<sup>st</sup> law of thermodynamics (energy input = energy output)  
combined with  
integrated political objectives (minimisation of primary heat demand)**

**The equivalence factors for energy are based on  
savings of primary fuels in dedicated power and/or heat plants  
and got to be used in the R1 formula for  $E_p$  (export plus self use) and  $E_i$   
with:**

**2.6 for electricity  
1.1 for heat**

**The equivalence factors are rounded results for energy as laid down in the  
BREF Waste Incineration (BREF WI)  
2.6316 for electricity (100%/38%)  
1.0989 for heat (100%/91%)**

## R1 formula boundary limits of a WtE facility



Reimann 2010

## **Importance of accurate NCV ( $E_w$ ) as denominator in the R1 formula**

**Many but not all of the plants have got a calculation model for NCV, delivered by the manufacturer of a plant, mostly for steering the incineration process; other ones use other equations for the NCV calculation**

**These NCV results show quite often great deviations to reality.**

**Therefore a NCV formula is laid down in the BREF WI which is not only a very effective control instrument of the NCVs found by all the different methods but is also a very good solution to determine the real NCV of waste**



## NCV formula out of BREF Waste Incineration, chapter 2, art. 2.4.1.2 and Annexes 10.4.2


$$\text{NCV} = (1.133 \times (m_{\text{st w}}/m) \times c_{\text{st x}} + 0.008 \times T_b) / 1.085 \quad (\text{GJ/tonne})$$

NCV = lower calorific value (NCV) of the incinerated waste with  $m_{\text{st w}}/m \geq 1$  (GJ/tonne)

$$m_{\text{st w}} = m_{\text{st x}} - (m_f \times (c_f / c_{\text{st x}}) \times \eta_b) \quad (\text{tonne steam/tonne MSW})$$

$m_{\text{st w}}$	=	amount of the steam produced from the waste in the same time period to $m_{\text{st x}}$ e.g. per year (tonne/yr)
$m_{\text{st x}}$	=	total amount of the steam produced in a defined time period e.g. per year (tonne/yr)
$m_f$	=	amount of supplementary fuel in the corresponding time period e.g. per year (tonne/yr)
$m$	=	mass of incinerated waste in the defined time period e.g. per year (tonne/yr)
$c_{\text{st x}}$	=	net enthalpy of steam i.e. enthalpy of steam minus enthalpy of boiler water (GJ/tonne)
$c_f$	=	net calorific value of the supplementary fuel that add to steam production (GJ/tonne)
$T_b$	=	temperature of flue-gas after boiler at 4 - 12% O <sub>2</sub> in flue-gas (°C)
0.008	=	specific energy content in flue-gas (GJ/tonne x °C)
1.133 and 1.085	=	are constants derived from regression equations
$\eta_b$	=	efficiency of heat exchange to the boiler (approx. 0.80)

**Note: From the measured amount of  $m_{\text{st w}}$  double counted steam quantities got to be deducted**  
e.g. steam for heating up of combustion air if it is extracted after the steam measuring device  
**not measured steam quantities got to be added**  
e.g. steam for sootblowing straight out of the drum or injection of water or NH<sub>4</sub>OH for SNCR



(Reimann 2005)

**Figure 1: Net Calorific Value (NCV)**

- calculated using the BREF-formula as well as indicated by the operator including NCV mean values weighted and not weighted for 97 W-t-E plants (status 2001-2004)


## Net Calorific Value (NCV) of MSW<sup>1)</sup> from the countries included in the CEWEP Energy Report II (status 2004-2007) as min., max. values and weighted averages

Country		Net Calorific Value (NCV) of MSW <sup>1)</sup> calculated by BREF Waste Incineration (BREF WI) <sup>2)</sup>		
		weighted average	min	max
		GJ/Mg MSW <sup>1)</sup>	GJ/Mg MSW <sup>1)</sup>	GJ/Mg MSW <sup>1)</sup>
Austria	AT	8.635	8.343	10.081
Belgium <sup>3)</sup>	BE	10.258	9.370	12.345
Czech Republic	CZ	8.921	8.693	9.220
Denmark	DK	10.547	9.532	12.420
France <sup>3)</sup>	FR	9.457	5.806	15.425
Finland	FI	11.939	(-)	(-)
Germany <sup>3)</sup>	DE	10.156	7.965	12.715
Hungary	HU	8.607	(-)	(-)
Italy	IT	10.171	8.619	14.701
Netherlands	NL	9.609	6.402	11.867
Portugal	PT	8.412	7.945	8.770
Spain <sup>3)</sup>	ES	9.128	8.050	10.221
Sweden <sup>3)</sup>	SE	11.462	9.316	14.357
UK	GB	8.442	(-)	(-)
Luxembourg	LU	10.469	(-)	(-)
Switzerland	CH	11.055	10.366	12.047
<b>total investigated</b>	<b>total</b>	<b>10.129</b>	<b>5.806</b>	<b>15.425</b>

<sup>1)</sup> 'municipal solid waste'(MSW) means waste from households as well as commercial, industrial and institutional waste, which, because of its nature and composition is similar to waste from households

<sup>2)</sup> BREF WI: Formula for NCV calculation see Chapter 2, article 2.4.2, pg. 83-84

<sup>3)</sup> 1 plant BE (biogas), 1 plant SE (co-combustion with wood chips and peat), 8 plants FR (no energy recovery/boiler or unfeasible data), 1 plant ES (co-combustion with gas), 1 plant DE (pyrolysis) have not been taken into account because not comparable with the investigated 231 European WtE plants.




▲ ordered by NCV

range 5.806-15.425

weighted average 10.129GJ/Mg

**Diagram 4:**

**Net calorific value (NCV)<sup>1)</sup> of MSW<sup>2)</sup> of 231 WtE plants in the CEWEP Energy Report II (status 2004-2007), classified into 3 European Regions such as Northern, Middle and Southern Europe as min., max. values and weighted**



<sup>1)</sup> BREF Wt: Formula for NCV calculation see Chapter 2, article 2.4.2, pg. 83-84

<sup>2)</sup> mixed municipal waste (MSW) means waste from households as well as commercial, industrial and institutional waste, which, because of its nature and composition is similar to waste from households


# Produced energy (exported plus self used) (Ep) as numerator in the R1 formula

**Overview on numbers, throughput and NCV of MSW, total energy input and specific produced energy and energy demand for all 231 WtE plants as well as classified into 75 plants only electricity, 41 plants only heat and 115 plants CHP producing (status 2004-2007)**

Kind of energy recovery	tag	all investigated WtE plants not classified	% of A/A; B/B; E/E; (F <sub>1</sub> to F <sub>5,5</sub> )/D	tag	WtE plants only heat producing	% of A/A; B/B; E/E; (F <sub>1</sub> to F <sub>5,5</sub> )/D1	tag	WtE plants only electricity producing	% of A2/A; B2/B; E2/E; (F <sub>2,1</sub> to F <sub>2,5,5</sub> )/D2	tag	WtE plants CHP producing	% of A3/A; B3/B; E3/E; (F <sub>3,1</sub> to F <sub>3,5,5</sub> )/D3
Number of WtE plants	[-]	231	100	A1	41	17.7	A2	75	32.5	A3	115	49.8
Total throughput of MSW	Mg/year	45,518,189	100	B1	4,568,219	10.0	B2	12,722,342	28.0	B3	28,227,628	62.0
Specific energy input by MSW (without import) (NCV)	MWh abs. /Mg	2.814	-	C1	2.953	-	C2	2.618	-	C3	2.867	-
Total specific energy input (included import)	MWh abs. /Mg	2.876	-	D1	3.056	-	D2	2.664	-	D3	2.922	-
Total energy input (incl. import)	MWh abs. /Mg	130,910,312	100	E1	13,960,477	10.7	E2	33,892,319	25.9	E3	82,481,129	63.0
Specific electricity produced (Ep)	MWh abs. /Mg	0.413	14.4	F <sub>1,1</sub>	0	0.0	F <sub>2,1</sub>	0.551	20.7	F <sub>3,1</sub>	0.416	14.2
Specific electricity exported	MWh abs. /Mg	0.318	11.1	F <sub>1,2</sub>	0	0.0	F <sub>2,2</sub>	0.457	17.2	F <sub>3,2</sub>	0.306	10.5
Specific heat prod. and used (Ep)	MWh abs. /Mg	1.202	41.8	F <sub>1,3</sub>	2.486	81.3	F <sub>2,3</sub>	0.400	15.0	F <sub>3,3</sub>	1.341	45.9
Specific heat exported	MWh abs. /Mg	0.790	27.5	F <sub>1,4</sub>	2.111	69.1	F <sub>2,4</sub>	0.000	0	F <sub>3,4</sub>	0.932	31.9
Spec. total energy demand ((part of Ep)+Ef+Ei(th+el)) <sup>1)</sup>	MWh abs. /Mg	0.569	19.8	F <sub>1,5</sub>	0.521	17.0	F <sub>2,5</sub>	0.530	19.9	F <sub>3,5</sub>	0.592	20.3
Incl. in total spec. demand as Ef	MWh abs. /Mg	0.015	0.5	F <sub>1,5,1</sub>	0.018	0.6	F <sub>2,5,1</sub>	0.010	0.4	F <sub>3,5,1</sub>	0.009	0.3
Incl. in total spec. demand as Ei(el)	MWh abs. /Mg	0.019	0.7	F <sub>1,5,2</sub>	0.101	3.3	F <sub>2,5,2</sub>	0.004	0.2	F <sub>3,5,2</sub>	0.017	0.6
Incl. in total spec. demand as Ei(th)	MWh abs. /Mg	0.028	1.0	F <sub>1,5,3</sub>	0.027	0.9	F <sub>2,5,3</sub>	0.022	0.8	F <sub>3,5,3</sub>	0.031	1.1
Incl. in total spec. electricity prod. as Ep (self used electricity)	MWh abs. /Mg	0.095	3.3	F <sub>1,5,4</sub>	0.000	0.0	F <sub>2,5,4</sub>	0.094	3.5	F <sub>3,5,4</sub>	0.111	3.8
Incl. in total spec. heat prod. as Ep (self used heat)	MWh abs. /Mg	0.412	14.3	F <sub>1,5,5</sub>	0.375	12.3	F <sub>2,5,5</sub>	0.400	15.0	F <sub>3,5,5</sub>	0.424	14.5

<sup>1)</sup> In the energy self used (demand) are taken into account beside the imported energy 100% i.a. energy self used for boiler water heating up from an average temperature basis of 70°C to the boiler water temperature and 100% energy self used for heating up of combustion air as well as the steam to soot blowers, SCR re-heating, pipe heating, building heating; because the possibility to take local conditions e.g. climate, market for heat etc. as mentioned in Directive 2008/98/EC – Interpretation and adaptation to technical progress, Article 38, 1. para. 2 of 19 November 2008 is up to now not yet worked out, it therefore could not be taken into account.

## R1 efficiency factors for the investigated 231 WtE plants with distinction between the categories size, region and energy recovery



<sup>1)</sup> R1 calculation in accordance to the Directive 2008/98/EC (WFD), Annex II, with equivalence factors: for electricity produced and imported 1 MWh el = 2.6 MWhel equ; for heat produced and commercially used 1 MWh th = 1.1 MWhth equ and according to BREF WI for imported fuel 1 MWh fuel = 1.0 MW fuel equ. The heat used by the plant to treat the waste includes all uses of steam, particularly steam to the deaerator and to the air heater.

## Optimisation potential for R1

**The kind of operation and type of energy recovery of existing, new or rebuilt plants are decisive parameters for R1. In many cases influenceable by the operator of a plant.**

**Optimisation of thermal process/operation** (low to medium investment),  
e.g. by reduction of combustion air/O<sub>2</sub> content, avoidance of fouling in boiler, low flue gas temperature after boiler (200°C), increase of availability by effective processing



**Optimisation of the plant consumption in primary energy/fuels** (low to medium investment),  
e.g. by less combustion air during start up and shut down, optimized distribution and addition of combustion air to keep the combustion temperature at low NCV of waste without using primary fuels, heating up of flue gases for SCR instead with primary fuels with self produced steam.

**Increase in electricity production** (medium to high investment),  
e.g. more often cleaning of heat exchanger tubes of air condenser, cooling by water sprinkling over the air condenser during periods with high temperatures, using heat energy in flue gas for heating up boiler water, increase of boiler water temperature, use of Rankine Cycles, new turbine, new boiler with higher steam parameters (often no optimal equipment available for small plants/units).

**Increase in heat utilisation as steam, district heat or district cool** (medium to very high investment):  
e.g. by using heat better also condensing energy out of the flue gas for heating up the backflow of district heating or for condensate heating up, instead of air or water cooling of LP steam in condensers use of this steam for useful purposes (i. a. drying of sewage sludge).  
By far the most effective mean but not possible everywhere since it depends essentially on the presence of customers for heat, and the length of the heating (cooling) period (climate zone) and the local energy market conditions (prices).



## Energy Recovery from Flue Gas by Temperature Reduction combined with Steam Condensation



65°C → 146 g H<sub>2</sub>O/m<sup>3</sup>

45 °C → 65 g H<sub>2</sub>O/m<sup>3</sup> → Δ 81 g H<sub>2</sub>O/m<sup>3</sup>

100.000 m<sup>3</sup> flue gas/h with 16% saturated steam  
→ 1,3 m<sup>3</sup> condense water/h

## **Optimisation potential for R1**

**The size of an existing plant, an important parameter for R1, cannot be influenced by the operator of a plant. This is only an option for the planning of new installations or rebuilding of plants.**

**The location of a plant in a European geographical region (climate zone), the most important parameter for R1, can neither be influenced by the operator of a plant nor by the designer of new installations or rebuilding of plants.**

**Therefore the adaption of a R1 climate factor is in discussion in the EU Commission**

**Because currently a R1 guideline is in the works by the EU Commission some of the results and statements may change but only marginally**

## Necessary efficiency rates to reach R1 of at least 0.60 (0.65)

All data in % of the total energy input ( $E_w$  including  $E_f + E_i$  (el+th))

### Solely electricity production incl. self used heat

External electricity demand ( $E_i$  el) 0.2%, external heat demand ( $E_f$ ) 0.6%, ( $E_i$  th)1.0%,  
produced ( $E_p$  el) **20.3%**, (produced  $E_p$  th self used) **6.8%** for R1 = **0.60**  
prod. ( $E_p$  el) **22.1%**, (prod.  $E_p$  th) **6.8%** for R1 = **0.65**

### Solely heat/steam production

External electricity demand ( $E_i$  el) 3.4%, external heat demand ( $E_f$ ) 0.6%, ( $E_i$  th)1.0%  
produced ( $E_p$  el) **0%**, (produced  $E_p$  th) **60.6%** for R1 = **0.60**  
prod. ( $E_p$  el) **0%**, (prod.  $E_p$  th) **64.5%** for R1 = **0.65**

### CHP production (only as an example)

External electricity demand ( $E_i$  el) 0.2%, external heat demand ( $E_f$ ) 0.6%, ( $E_i$  th)1.0%,  
produced ( $E_p$  el) **12.0%**, (produced  $E_p$  th) **26.4%** for R1 = **0.60**  
prod. ( $E_p$  el) **12.0%**, (prod.  $E_p$  th) **30.7%** for R1 = **0.65**

**For MSW plants beside R1 proof also the BATs 61- 63 of BREF Waste Incineration concerning energy recovery have to be met**

**BAT 61: for new installatons: total energy heat/ steam export of **1.9 MWh/Mg MSW (65.5%)**  
based on an average energy input of 2.9 MWh/Mg MSW**

**BAT 62: where less than 1.9 MWh/Mg MSW export at an energy input of 2.9 MWh/Mg MSW:**

**a.) electricity production:**

**0.40 (13.8%) – 0.65 (22.4%) MWhe/Mg MSW plus additional heat/steam supply as far as practible in the local conditions**

**b.) generation of at least the same amount of electricity as the annual average electricity demand of the entire installation**

**BAT 63: Reduction of average installation electricity demand below **0,150 MWhe/Mg MSW****

## Conclusions

**By increasing the R1 efficiency factor comparing to the recent situation this results i. a. in a positive contribution to the national energy supply, in saving of resources combined with a reduction potential of CO2 emissions**

**By the comparison of the R1 results between the individual plants a competition to be better and more effective than another one is started for the benefit of the environment**

**In the case that in the future Industrial Emission Directive (IED) BREFs will become mandatory than also the BATs of BREF Waste Incineration (WI) and BREF Energy Efficiency (ENE) will be decisive for energy recovery.**

**In the case that a WtE plant reaches the R1 target this plant fullfills automatically almost the upper limits of the energy BATs of BREF WI.**

**Only in case that an individual WtE plant reaches the R1 target this plant may treat beside waste mentioned for disposal also waste for recovery.**

**More information about the energy flows, NCV and R1 of 231 European  
WtE plants are published in the  
CEWEP Energy Report II (Status 2004-2007)  
<http://www.cewep.eu/studies/climate-protection>**

**Thank you for your attention**