

THE LONG-TERMS EFFECTS OF DIFFERENT BIOMASS QUALITIES IN A GRATE BOILER

Morten Fossum, Trondheim Energi Fjernvarme AS

CONTENT


- > Biomass combustion unit
- > Fuels tested
- > Results

COMBUSTION UNIT


Grate combustion unit with hot water boiler

- Marienborg plant
 - Supplier: KMW
 - Capacity: 9 MW
 - Installed: 2002
 - Designed for dry biomass fuel, but modification in refractory lining is performed in order to handle more moist fuel
 - Down-stream flue gas tube boiler
 - Multi cyclon
 - Bag house filter
- Klæbu plant
 - Supplier: Hotab
 - Capacity: 1.5 MW
 - Installed: 2004
 - Designed for dry biomass
 - Down-stream flue gas boiler
 - Multi cyclon

COMBUSTION UNIT - MARIENBORG



COMBUSTION UNIT - KLÆBU



FUELS TESTED

- > Briquettes
 - 100% sorted demolition wood


- > Mixture of briquettes and wood chips
 - App. 42 % briquettes and 58 % wood chips

- > Wood chips
 - Wood chips I: Mixture of Norwegian spruce and Baltic hardwood
 - Wood chips II: Norwegian spruce

- > Wood chips
 - 100% sorted demolition wood

- > Pellet
 - Tests were cancelled due to problems with the feeding system.

FUELS TESTED



Briquetts



Wood chips, mix of Norwegian spruce and Baltic hardwood



Wood chips, Norwegian spruce



Pellet

FUEL ANALYSIS - MARIENBORG

Fuel type	Briquettes	Wood chips I	Wood chips II	Pellet
Moisture (% wt)	10.9	39.0	39.0	8.7
Ash (% wt, d.b.)	2.2	0.95	0.6	0.37
S (% wt, d.b.)	0.087	0.014	0.012	0.006
Cl (% wt, d.b.)	0.041	0.005	0.008	0.0016
N (% wt, d.b.)	0.5	<0.3	<0.3	<0.3
Heff (MJ/kg w.b.)	16.5	10.5	10.3	17.1
Ash melting temp (° C)	1060 - 1118	1145-1325	1150-1210	1200

FUEL ANALYSIS - KLÆBU

Fuel type	Wood chips from sorted waste wood	Residue products from saw mill etc.
Moisture (% wt)	13.4	11.1
Ash (% wt, d.b.)	1.4	0.3
S (% wt, d.b.)	0.038	0.01
Cl (% wt, d.b.)	0.0054	<0.01
N (% wt, d.b.)	0.3	<0.2
Heff (MJ/kg w.b.)	16.3	16.8

FUEL AND ASH ANALYSIS

--> Metals

- Al, As, B, Ca, Cd, Co, Cr, Cu, Fe, Hg, K, Mg, Mn, Mo, Na, Ni, P, Pb, Sb, Se, Sn, Tl, V, Zn

--> Lanthanides

- Ce, Dy, Er, Eu, Gd, La, Lu, Nd, Pr, Sm, Tb, Tm

FUEL ANALYSIS

	2003-466- (mg/kg)								LOD
	36 Bl. Brik 7-17/10	37 Bl. Brik 22- 29/10	38 Bl. flis 22- 29/10	39 Bl. flis 4-7/11	40 Bl. Flis 10- 13/11	41 Bl. flis 18- 20/11	42 Br. 42 levirke	43 Bl. Pellet 18- 20/11	
Al	366	414	39	43	113	58	40	30	2
As	71	63	<2	<2	<2	<2	<2	<2	2
B	<1	3	3	3	2	4	4	1	1
Ca	2070	1885	1525	1759	1613	1303	1649	804	10
Cd	<1*	<1*	<0,1	<0,1	<0,1	<0,1	<0,1	0,2	0,1
Co	1,4	0,8	<0,3	<0,3	<0,3	<0,3	<0,3	<0,3	0,3
Cr	57	60	0,2	0,3	0,3	0,3	<0,2	0,4	0,2
Cu	48	50	1,0	1,2	1,6	1,3	1,4	1,2	0,4
Fe	580	608	54	69	145	91	56	39	5
Hg	0,11	0,12	<0,01	<0,01	<0,01	<0,01	0,03	<0,01	0,01
K	532	689	685	833	786	703	986	422	5
Mg	415	385	196	234	237	188	284	118	1
Mn	91,2	85,0	106	62,6	69,9	92,1	28,9	115	0,3
Mo	<1	<1	<1	<1	<1	<1	<1	<1	1
Na	330	431	15**	17**	20**	18**	11**	26	5**
Ni	3,8	1,5	<0,3	<0,3	<0,3	0,3	<0,3	<0,3	0,3
P	52	54	70	110	104	83	171	35	2
Pb	37,3	31,2	0,7	<0,5	<0,5	<0,5	<0,5	<0,5	0,5
Sb	<2	<2	<2	<2	<2	<2	<2	<2	2
Se	<2	<2	<2	<2	<2	<2	<2	<2	<2
Sn	0,6	0,9	<0,4	<0,4	<0,4	<0,4	<0,4	<0,4	0,4
Tl	0,7	<0,3	0,6	0,7	0,5	0,5	0,7	0,8	0,3
V	1,3	1,7	<0,3	<0,3	0,3	<0,3	<0,3	0,3	0,3
Zn	418	334	19	17	16	21	17	13	4
Ce	0,41					0,048	0,062	0,032	0,0005
Dy	0,027					<0,007	<0,007	<0,007	0,007
Er	0,018					0,003	0,002	<0,002	0,002
Eu	0,007					0,001	0,0009	<0,001	0,001
Gd	0,032					<0,01	<0,01	<0,01	0,01
La	0,21					0,024	0,037	0,018	0,0004
Lu	0,002					0,0003	0,0002	0,0003	0,0002
Nd	0,16					0,023	0,019	0,015	0,005
Pr	0,050					0,006	0,009	0,0039	0,0005
Sm	0,034					0,005	0,004	0,0029	0,0003
Tb	0,007					0,001	0,0007	0,0005	0,00005
Tm	<0,004					<0,004	<0,004	<0,004	<0,004

RESULTS

--> Emissions to air

-- Average values, mg/Nm³, @ 11 % O₂, dry flue gas.

	Briquettes	Briquettes/ wood chips	Wood chips
NO _x	166.7	168.4	125.0
SO _x	28.9	17.4	0.1
CO	18.3	15.0	19.5
HCl	4.8	4.6	4.3
HF	6.8	4.1	7.2
SO ₂	54.8	22.4	5.0

RESULTS

--> Emissions to air

-- Average values, $\mu\text{g}/\text{Nm}^3$ (pg), @ 11 % O₂, dry flue gas.


Fuel	Briquettes	Briquettes/ Wood chips	Wood chips
Component			
Hg	2.9	1.1	<1
Co	<0.5	<0.5	<0.5
Cr	0.9	0.7	1.2
Cu	3.9	2.4	2.4
Mn	1.0	1.8	1.7
Ni	<1	<1	7.2
Pb	<10	<10	<10
Sb	<2.5	<2.5	<2.5
Ti	<1	<1	<1
V	<1	<1	<1
Cd	<1	<1	<1
As	<5	<5	<5
Dioksin ^{(1) (2)}	751.3	627.5	446.9

RESULTS

--> Ash analysis

- Average values, %wt

Briquettes and wood chips



OPERATIONAL EXPERIENCES

--> Marienborg plant

- Briquettets and briquettes/wood chips
 - Severe slagging on grate
 - Fouling in the convective section of the boiler
 - High level of char in bottom ash

--> Klæbu plant

- Wood chips from sorted waste wood
 - Serious sintering problems on the grate and the furnace walls
 - Fouling in the convection section of the boiler
 - Operation between stop for cleaning was 8-10 days, for virgin wood material the plant runs for about 12 weeks before cleaning is needed.

OPERATING EXPERIENCES MARIENBORG



OPERATING EXPERIENCES KLÆBU

